



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

Order ID: 061604482
Customer ID: SWTC10
Customer PO:
Project ID:

Attn: Jim O'Hara
Ambient Water Treatment
99 Jericho Turnpike
Suite 304
Jericho, NY 11753
Project: HCC005 Legionella 20160502

Telephone: (516) 342-1964
Fax: (516) 908-6470
Received Date: 05/02/2016
Processed Date: 05/02/2016
Analyzed Date: 05/11/2016

Level 2 Legionella Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
061604482-0001	1 A-Building	100	0.25	Direct Plating	None Detected	ND
061604482-0002	2 C-Building	100	0.25	Direct Plating	None Detected	ND


Daniel Clarke, Microbiology Laboratory
Manager
or Other Approved Signatory

*Legionella confirmations are carried out using a direct fluorescent antibody stain for Legionella pneumophila serogroup (1-14) and a stain for 20 other Legionella species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-Legionella bacterial counts are found during primary isolation, or suspected of containing high non-Legionella counts such as from a swab, bulk or non-potable water source. Samples high in non-Legionella bacteria may obscure the detection of Legionella.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY

Initial Report From: 05/11/2016 10:27:45